

- 1- After removing the unit from the box, open the timer box and inspect the timer pins. You will see four sets of timer pins. The pins are preset for 3 hours of running time. This setting is adequate for a crawlspace from 1,500 to 2,000 square feet. The pins can be adjusted to run longer or shorter depending on the square footage of your crawlspace. Please check our web site at [ventthecrawl.com](http://ventthecrawl.com) for more information.
- 2- Remove the bug screen from the existing foundation vent and discard. Zeus will provide the screen. The selected vent should be located at the closest accessible vent. See "Foundation Vent Notice" on other side.
- 3- The 8" x 16" area behind the vent opening will be used to support the exhaust edge of the Zeus unit. The 4" masonry lip should cradle the exhaust flange of the unit. The front fiberglass strapping is not required if there is adequate support.
- 4- Cut the 2 fiberglass straps close to the exhaust vent side. Use the attached strap portion to secure the unsupported end of the unit to the floor system with the Simplex nails. Zeus should now be supported by the foundation block and the rear fiberglass straps.
- 5- Using the provided can of foam [ Read manufacturers' instructions], seal the voids around the Zeus exhaust flange.
- 6- Have a licensed Electrician install a 120 volt - 15 or 20 amp receptacle with 48" of the unit for electrical power.

**WARNING:** The unit vent must remain permanently open. Failure to do so will result in damage to the unit.

The **ZEUS** unit's performance can be greatly enhanced by incorporating our **Moisture Scrubber** system. Please visit our web site for details, [ventthecrawl.com](http://ventthecrawl.com)





## Foundation Vent Notice



If your foundation Vent resembles the picture above, you must discard it entirely. Using this type of foundation vent will damage the *Zeus Unit* and void your warranty.




REMOVE  
SCREEN

Replace the foundation vent with the one pictured above. Be sure to remove the screen prior to installation to prevent damage to the *Zeus Unit*. Failure to do so will void your warranty. The *Zeus Unit* comes with a screen designed for the proper air flow ventilation. The only vent that may have to be replaced will be the *Zeus Unit* vent.

If you need assistance on foundation vent selection, please email Vent the Crawl at [ventthecrawl@earthlink.net](mailto:ventthecrawl@earthlink.net).

(Home Depot model # 142494)  
(Lowes model # 17184)



200 Gatewood Circle  
Athens, Georgia 30607  
706.548.2155  
[Ventthecrawl.com](http://Ventthecrawl.com)